



State of New Hampshire  
DEPARTMENT OF ENVIRONMENTAL SERVICES

6 Hazen Drive, P.O. Box 95, Concord, NH 03302-0095  
(603) 271-3503 FAX (603) 271-5171



April 17, 2002

Moe Cassanelli  
Day's Auto Salvage  
162 Somersworth Road  
Rollinsford, NH 03869

**LETTER OF DEFICIENCY WSEB# 02-16**  
CERTIFIED MAIL# 7099 3400 0002 9772 1992

Subject: Rollinsford – Day's Auto Salvage, Somersworth Road (DES # 200107003)

Dear Mr. Cassanelli

The records of the Department of Environmental Services (DES) show that Day's Auto Salvage (facility) is a motor vehicle facility with floor drains that discharge to the ground. NH Administrative Rule Env-Ws 1500 *Groundwater Discharge Permit and Registration Rule*, specifically Env-Ws 1503.04, prohibits the discharge to the ground from a floor drain in an area where a regulated contaminant is used or stored. Since oil and other regulated contaminants are located throughout the facility, the discharge from the floor drains is in violation of NH Administrative Rule 1503.04.

DES believes Day's Auto Salvage can correct the violations and prevent future violations by taking one of the following actions:

1. By May 10, 2002, determine which of the following three corrective actions will be taken:
  - a. Permanently cease the discharge by sealing the drain(s) with concrete and notify DES of the action; or
  - b. Re-route the discharge to a holding tank (State registration required); or
  - c. Re-route the discharge to the municipal sewer system (local approval may be required).
2. By May 20, 2002, submit to DES for review a letter indicating which option has been chosen and the implementation timetable to complete the chosen option.

In the event compliance is not achieved within this period, DES may take further enforcement action, including issuing an order requiring the deficiencies to be corrected, initiating an administrative fine proceeding, and/or referring the matter to the NH Department of Justice for imposition of appropriate penalties.

The requested information should be addressed as follows:

Mitchell D. Locker  
Department of Environmental Services  
Water Supply Engineering Bureau  
6 Hazen Drive, PO Box 95  
Concord, NH 03302-0095

COPY

**Letter of Deficiency WSEB# 02-16**

Day's Auto Salvage

April 17, 2002

Page 2 of 2

Please contact Mitchell D. Locker by phone at (603) 271-2858 or by e-mail at [mlocker@des.state.nh.us](mailto:mlocker@des.state.nh.us), if you have any questions regarding this letter.

Sincerely

**COPY**

Anthony Giunta, P.G., Administrator  
Water Supply Engineering Bureau

Enclosure: Holding Tank Registration Form

✓Gretchen Rule, DES Legal Unit  
Sarah Pillsbury, WSEB  
Rollinsford Health Officer  
File

MDL/ml/h:\swp\uic\2001mdl\enforce\200107003LoD